

# **Public Notice to Customers**

## **Maximum Contaminant Level Violation MCL, AVERAGE / ARSENIC**

The Texas Commission on Environmental Quality (TCEQ) has notified the **EOL WSC** that the drinking water being supplied to customers has exceeded the Maximum Contaminant Level (MCL) for arsenic. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic at 0.010 milligrams per liter (mg/L) based on a running annual average, and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in **quarter three 2018 of 0.017 mg/L for EP002, Well#2, located at 9219 Elk Road.**

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

We are currently waiting on funding to begin construction for a pipeline to receive water from the City of Waco to blend with in order to lower our arsenic level. EOL WSC continues to follow the guidelines set by TCEQ and the EPA for notification and water sample requirements.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, you may contact:

**Fred E. Kubitz, Jr. (254)744-3388 or Cassie Pantelici (254)863-0404**

Posted/Delivered on: **11/27/2018**

**EOL WSC – PWS#1550025 3<sup>rd</sup> Qtr Notice 2018**